



INFRARED HEATING REQUIREMENTS

1. (1) LTU75-30 VENTED SPACE-RAY INFRARED HEATERS. INSTALL AT 12 FT. ABOVE FINISHED FLOOR.
2. (1) SPACE-RAY HIGH HUMIDITY ENVIRONMENT THERMOSTAT MOUNTED 56" ABOVE FINISHED FLOOR.
3. HEATERS SHALL BE "PULL THROUGH" SYSTEMS (VACUUM) WITH CAST IRON BURNER AND CALORIZED EMITTER TUBES.
4. HEATER, THERMOSTAT LOCATIONS SUBJECT TO FIELD VERIFICATION & COORDINATED WITH OTHER EQUIPMENT IN THE BUILDING.
5. CONSULT HEATER SPECIFICATION SHEET AND I & O INSTRUCTIONS. FOR FURTHER INFORMATION PLEASE VISIT WWW.SPACERAY.COM



Title: **AMOCO CAR WASH**

INSTALLATION DETAIL-985

Drawn By: **RJ Harrington** Date: **08 MAR 06**