



INFRARED HEATING REQUIREMENTS

1. (2) LTS100-30 VENTED SPACE-RAY INFRARED HEATERS WITH 10' DEFLECTOR ASSEMBLY. INSTALL AT 13 FT. ABOVE FINISHED FLOOR.
2. (1) SPACE-RAY RT SERIES THERMOSTAT MOUNTED 56" ABOVE FINISHED FLOOR.
3. HEATERS SHALL BE "PULL THROUGH" SYSTEMS (VACUUM) WITH CAST IRON BURNER AND CALORIZED EMITTER TUBES.
4. HEATER, THERMOSTAT LOCATIONS SUBJECT TO FIELD VERIFICATION & COORDINATED WITH OTHER EQUIPMENT IN THE BUILDING.
5. CONSULT HEATER SPECIFICATION SHEET AND I & O INSTRUCTIONS. FOR FURTHER INFORMATION PLEASE VISIT WWW.SPACERAY.COM



Title: GREENHOUSE HEATING
INSTALLATION DETAIL-1040

Drawn By: R.J. Harrington

Date: 16 JUN 05