



INFRARED HEATING REQUIREMENTS

1. (2) CB80-15 VENTED SPACE-RAY INFRARED HEATERS. INSTALL AT 12 FEET ABOVE FINISHED FLOOR.
2. (2) SPACE-RAY HIGH HUMIDITY ENVIRONMENT THERMOSTATS MOUNTED 5'6" ABOVE FINISHED FLOOR.
3. HEATERS SHALL BE "PULL THROUGH" SYSTEMS (VACUUM) WITH CAST IRON BURNER AND CALORIZED EMITTER TUBES.
4. HEATER, THERMOSTAT LOCATIONS SUBJECT TO FIELD VERIFICATION & COORDINATED WITH OTHER EQUIPMENT IN THE BUILDING.
5. CONSULT HEATER SPECIFICATION SHEET AND I & O INSTRUCTIONS. FOR FURTHER INFORMATION PLEASE VISIT WWW.SPACERAY.COM



Title: **INDOOR SWIMMING POOL
INSTALLATION DETAIL-1034**

Drawn By: **RJ Harrington** Date: **16 JUN 05**